



OREGON DEPARTMENT OF ENVIRONMENTAL QUALITY
Underground Storage Tank Program

UST Public Record – General Program Information for FFY 2011

General Information

Public Record Posted Date: October 25, 2011

Total Number of UST Facilities: 1964
 Total Number of USTs: 5758

Summary Information for On-Site Inspections

Number of UST Facilities Inspected: 521
 Inspection Period Dates: 10/1/10 to 9/30/11
 Percent Compliance (Combined Measure): 89.9

NOTE: Tank, facility and on-site inspection information is based on underground storage tanks (USTs) regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those identified in 40 CFR 280.10(b) and 280.10(c) as excluded or deferred USTs. Emergency generator USTs are included. On-site inspections measure significant operational compliance (SOC) as defined by the Environmental Protection Agency.

Summary Information for Releases

Number of Confirmed UST Releases: 46
 Release Reporting Period Dates: 10/1/10 to 9/30/11

Summary Information for Release Sources and Causes

Source			Causes													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
#	%		#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	16	41.5	0	0	0	0	0	0	9	23	0	0	0	0	7	18.5
Piping	2	5	0	0	0	0	1	2.5	0	0	0	0	0	0	1	2.5
Dispenser	3	7.5	1	2.5	2	5	0	0	0	0	0	0	0	0	0	0
STP	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Delivery Problem	7	18	2	5	4	10.5	1	2.5	0	0	0	0	0	0	0	0
Other	11	28	1	2.5	1	2.5	0	0	0	0	0	0	0	0	9	23
Totals	39	100	4	10	7	18	2	5	9	23	0	0	0	0	17	44

= number, % = percent of total number – rounded to the nearest 0.5% for readability

NOTES:

- (1) The sources of the releases at 7 of the 46 confirmed release sites are unknown.
- (2) Release, source and cause information is based on USTs regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those USTs identified in 40 CFR 280.10(b) as excluded USTs. USTs

deferred in 40 CFR 280.10(c) and those used for emergency power generation (deferred from release detection by 40 CFR 280.10(d)) are included as part of the public record.

- (3) Source and cause data was collected at the time the release was reported either on-line or by phone and entered into the Leaking Underground Storage Tank Database. Project managers may update the data as additional information on the source and cause of the release becomes available.
- (4) Site specific information on releases can be found on DEQ's LUST Public Lookup table found on-line at <http://www.deq.state.or.us/lq/tanks/lust/LustPublicLookup.asp>. Site specific information on compliance and releases can also be obtained by contacting DEQ regional tank staff.

Contacting DEQ Regional Tank Staff

Tank Staff are available at the following offices:

In Northwest Oregon (Clatsop, Clackamas, Columbia, Multnomah, Tillamook and Washington counties):

- Portland, 2020 SW Fourth Ave., Suite 400
503-229-5263

In Western Oregon (Benton, Coos, Curry, Douglas, Jackson, Josephine, Lane, Lincoln, Linn, Marion, Polk and Yamhill counties):

- Salem office: 750 Front St. NE, Suite 120
503-378-8240
- Eugene office: 165 East 7th Avenue, Suite 100
541-686-7838
- Coos Bay office: 381 N. Second Street
541-269-2721

In Eastern Oregon (Baker, Crook, Deschutes, Gilliam, Grant, Harney, Hood River, Jefferson, Klamath, Lake, Malheur, Morrow, Sherman, Umatilla, Union, Wallowa, Wasco and Wheeler counties):

- The Dalles office: Columbia Gorge Community College, 400 E. Scenic Drive, Building 2
541-298-7255