

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM  
 WASTE DISCHARGE PERMIT**

Oregon Department of Environmental Quality  
 Northwest Region Office  
 2020 SW 4<sup>th</sup> Avenue, Suite 400, Portland, OR 97201  
 Telephone: (503) 229-5263

Issued pursuant to ORS 468B.050 and the Federal Clean Water Act

**ISSUED TO:**

Permittee:

Sanders Wood Products, Inc.  
 dba RSG Forest Products, Liberal  
 P. O. Box 169  
 Molalla, OR 97038

**SOURCES COVERED BY THIS PERMIT:**

Type of Waste

Saw contact cooling water,  
 compressor cooling water, pressure  
 washing/equipment cleaning  
 wastewater, boiler blowdown and  
 storm water runoff

Outfall  
 Number

001

Outfall  
 Location

R.M. 9.8  
 (Molalla River)

**PLANT TYPE AND LOCATION:**


Sawmill  
 28890 Highway 213  
 Liberal, Oregon

**RECEIVING STREAM INFORMATION:**

Basin: Willamette  
 Sub-Basin: Pudding-Molalla  
 Receiving Stream: Unnamed ditch to Molalla River  
 County: Clackamas  
 LLID: 1227171452976-9.8-1

EPA REFERENCE NO : OR 002130-0

Issued in response to Renewal Application No. 9973505 received March 4, 2008.

  
 \_\_\_\_\_  
 Greg Geist  
 Manager, Water Quality Source Control - Northwest Region

6/8/10  
 \_\_\_\_\_  
 Date

**Permitted Activities**

Until this permit expires or is modified or revoked, the permittee is authorized to construct, install, modify or operate a wastewater collection, treatment, control and disposal system and discharge to public waters adequately treated wastewaters only from the authorized discharge point or points established in Schedule A and only in conformance with all the requirements, limitations, and conditions set forth in the attached schedules as follows:

	<u>Page</u>
Schedule A - Waste Discharge Limitations	2
Schedule B - Monitoring and Reporting Requirements	4
Schedule C - Compliance Conditions and Schedules	5
Schedule D - Special Conditions	6
Schedule E - Industrial Pretreatment	N/A
Schedule F - General Conditions	7-15

Unless specifically authorized by this permit, by another NPDES or WPCF permit, or by Oregon Administrative Rule, any other direct or indirect discharge to waters of the state is prohibited, including discharge to an underground injection control system.

**Schedule A  
 Waste Discharge Limitations**

- Outfall 001:** Discharge of saw contact cooling water, compressor cooling water, boiler blowdown, pressure washing/equipment cleaning wastewater and storm water runoff to a ditch/unnamed tributary of the Molalla River.

Parameter	Limitation	
Floating Solids	No visible discharge	
Oil & Grease Sheen	No visible sheen	
Oil & Grease	15 mg/L (daily maximum)	10 mg/L (monthly average)
pH	Within the range of 6.0 – 9.0	

- Compliance Point.** Outfall 001 is defined as the overflow from the storm water detention pond. Sampling must be conducted and compliance will be determined prior to the discharge mixing with other waters in the ditch/unnamed tributary.
- Mixing Zone:** No wastes may be discharged or activities conducted that cause or contribute to a violation of water quality standards in OAR 340-041 applicable to the Willamette basin except as provided for in OAR 340-045-0080 and the following regulatory mixing zones:  
  
Outfall 001: The mixing zone is that portion of the receiving ditch from the discharge from the wastewater treatment system to within 50 feet of the downstream property line of the mill site.
- Storm Water Pollution Control Plan:** The permittee must implement its updated Storm Water Pollution Control Plan (SWPCP). The SWPCP must be kept current and updated to reflect any changes in facility operation and to address the requirements listed under Schedule D, Condition 1. Updates to the SWPCP must be submitted to the Department in accordance with Schedule C.
- Discharge Benchmarks for Outfalls 001:** Benchmarks are guideline concentrations not limitations. They are designed to assist the permittee in determining whether the SWPCP is effectively reducing pollutant concentrations in effluent. The following benchmark applies to outfall 001:

Parameter	Benchmark
Total Suspended Solids	130 mg/L

**6. Response to a Benchmark Exceedance**

- a) If a sampling result exceeds the benchmark value, the permittee must, within 30 calendar days of receiving the sampling results, investigate the cause of the elevated pollutant levels, review the SWPCP and submit an Action Plan for department approval.
- b) The purpose of this review is to determine if:
  - i) The SWPCP is being followed;
  - ii) There are alternative methods for implementing the existing site controls identified in the SWPCP; and
  - iv) Additional effective site controls are needed to address the parameters of concern.
- c) The Action Plan must contain the following:
  - i) The results of the review;
  - ii) The corrective actions the permittee will take to address the benchmark exceedance; and
  - iii) An implementation schedule including alternative methods for implementing existing site controls or methods for implementing additional effective site controls, if the site controls have not already been implemented.
- d) If the department does not comment on the Action Plan within 10 business days of its receipt, it is deemed approved. The department's approval of the Action Plan does not constitute compliance with this permit.
- e) Upon approval, the permittee must implement the corrective actions identified in the Action Plan within 60 calendar days, unless otherwise approved by the department.

**Schedule B**  
**Monitoring and Reporting Requirements**

**1. Monitoring Requirements**

- a) **Outfall 001:** Discharge of saw contact cooling water, compressor cooling water, boiler blowdown, pressure washing/equipment cleaning wastewater and storm water runoff to ditch/unnamed tributary of the Molalla River.

Parameter	Minimum Frequency	Sample Type
Flow	2/month	Estimate
Floating Solids	Daily, when operating	Visual Observation
Oil & Grease Sheen	Daily, when operating	Visual Observation
Total Suspended Solids	2/month	Grab
Oil & Grease	2/month	Grab
pH	2/month	Grab
Metals (copper, lead & zinc) <sup>1</sup>	2/year <sup>2</sup>	Grab

<sup>1</sup> Total Recoverable.

<sup>2</sup> Samples to be collected at least 60 days apart.

**2. Reporting Requirements**

- a) **Reporting Frequency.** Monitoring results must be reported on approved forms. The reporting period is the calendar month. Reports must be submitted to the Department's Northwest Region – Portland Office by the 15th day of the following month. Visual monitoring records must be maintained on-site and made available to the Department upon request.

The permittee must monitor the parameters as specified above at the locations indicated. The laboratory used by the permittee to analyze samples must have a quality assurance/quality control (QA/QC) program to verify the accuracy of sample analyses. If QA/QC requirements are not met for any analysis, the results must be included in the report, but not used in the calculations required by this permit. When possible, the permittee must re-sample in a timely manner for parameters failing QA/QC requirements, analyze the samples, and report the results.

- b) **Reporting of Non-Detect Sample Results.** For sample results below the detection level, the result shall be reported as "<DL" (e.g. <1.0). For sample results above the detection limit and below the quantitation limit, the results shall be reported as "eDL" (e.g., if the quantitation limit is 5.0, the detection limit is 1.0, and the analytical results give an estimated value of 3.0, then the value shall be reported as "e1.0").
- c) **Monitoring Records Prepared in Ink.** All bench sheets, laboratory analysis sheets, and other records to support the data reported on the Discharge Monitoring Report (DMR) shall be prepared in ink. Pencil entries or liquid paper corrections shall be prohibited by appropriate laboratory operating procedures. Changes to any supporting records that may be required to correct the original data shall be made by lining through the original data. The date of the change and the initials of the individual making the change shall be recorded in ink adjacent to the change.

**Schedule C**  
**Compliance Conditions and Schedules**

1. **Future updates to SWPCP.** Future updates to the SWPCP to reflect changes to the facility must be submitted to the Department within thirty (30) days after the completion of the change to the facility. Except for site controls that require capital improvements (see definition below), the SWPCP must be implemented within 90 days completion of the change to the facility. Site control activities that require capital improvements must be completed in accordance with the schedule set forth in the SWPCP.

*Capital Improvements* means the following improvements that require capital expenditures:

- i) Treatment best management practices including but not limited to settling basins, oil/water separation equipment, catch basins, grassy swales, detention/retention basins, and media filtration devices.
  - ii) Manufacturing modifications that incur capital expenditures, including process changes for reduction of pollutants or wastes at the source.
  - iii) Concrete pads, dikes and conveyance or pumping systems utilized for collection and transfer of storm water to treatment systems.
  - iv) Roofs and appropriate covers for manufacturing areas.
2. The permittee is expected to meet the compliance dates that have been established in this schedule. Either prior to or no later than 14 days following any lapsed compliance date, the permittee must submit to the Department a notice of compliance or noncompliance with the established schedule. The Director may revise a schedule of compliance if he determines good and valid cause resulting from events over which the permittee has little or no control.

**Schedule D**  
**Special Conditions**

**1. Solids Removal**

The permittee must remove solids from the storm water detention basin/oil-water separator on a regular basis as necessary for the effective operation of the detention basin. The permittee must also clean catch basins and oil-water separators at the site at regular intervals to minimize the carryover of pollutants. The minimum frequencies for cleaning these facilities must be specified in the SWPCP required by Schedule A, Condition 1. Solids removed from the basin must be disposed properly and must not be placed in an area where they may be discharged to waters of the state.

**2. Environmental Supervision and Management**

The permittee must designate an environmental supervisor to coordinate and carry out all necessary functions related to maintenance and operation of waste collection, treatment, and disposal facilities. This person must be allowed access to all information relevant to the generation of wastes in the various process areas.

**4. Notification**

The permittee must notify the Department's Northwest Region – Portland office at (503) 229-5263 in accordance with the response times contained in Schedule F of this permit of any malfunction so that corrective action can be coordinated between the permittee and the Department.

## **Schedule F General Conditions**

### **SECTION A. STANDARD CONDITIONS**

1. Duty to Comply with Permit

The permittee must comply with all conditions of this permit. Failure to comply with any permit condition is a violation of Oregon Revised Statutes (ORS) 468B.025 and the federal Clean Water Act and is grounds for an enforcement action. Failure to comply is also grounds for the Department to terminate, modify and reissue, revoke, or deny renewal of a permit.

2. Penalties for Water Pollution and Permit Condition Violations

The permit is enforceable by DEQ or EPA, and in some circumstances also by third-parties under the citizen suit provisions 33 USC §1365. DEQ enforcement is generally based on provisions of state statutes and EQC rules, and EPA enforcement is generally based on provisions of federal statutes and EPA regulations.

ORS 468.140 allows the Department to impose civil penalties up to \$10,000 per day for violation of a term, condition, or requirement of a permit. The federal Clean Water Act provides for civil penalties not to exceed \$32,500 and administrative penalties not to exceed \$11,000 per day for each violation of any condition or limitation of this permit.

Under ORS 468.943, unlawful water pollution, if committed by a person with criminal negligence, is punishable by a fine of up to \$25,000, imprisonment for not more than one year, or both. Each day on which a violation occurs or continues is a separately punishable offense. The federal Clean Water Act provides for criminal penalties of not more than \$50,000 per day of violation, or imprisonment of not more than 2 years, or both for second or subsequent negligent violations of this permit.

Under ORS 468.946, a person who knowingly discharges, places, or causes to be placed any waste into the waters of the state or in a location where the waste is likely to escape into the waters of the state is subject to a Class B felony punishable by a fine not to exceed \$200,000 and up to 10 years in prison. The federal Clean Water Act provides for criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment of not more than 3 years, or both for knowing violations of the permit. In the case of a second or subsequent conviction for knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both.

3. Duty to Mitigate

The permittee must take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit that has a reasonable likelihood of adversely affecting human health or the environment. In addition, upon request of the Department, the permittee must correct any adverse impact on the environment or human health resulting from noncompliance with this permit, including such accelerated or additional monitoring as necessary to determine the nature and impact of the noncomplying discharge.

4. Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and have the permit renewed. The application must be submitted at least 180 days before the expiration date of this permit.

The Department may grant permission to submit an application less than 180 days in advance but no later than the permit expiration date.

5. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause including, but not limited to, the following:

- a. Violation of any term, condition, or requirement of this permit, a rule, or a statute
- b. Obtaining this permit by misrepresentation or failure to disclose fully all material facts
- c. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge
- d. The permittee is identified as a Designated Management Agency or allocated a wasteload under a Total Maximum Daily Load (TMDL)
- e. New information or regulations
- f. Modification of compliance schedules
- g. Requirements of permit reopener conditions
- h. Correction of technical mistakes made in determining permit conditions
- i. Determination that the permitted activity endangers human health or the environment
- j. Other causes as specified in 40 CFR 122.62, 122.64, and 124.5

The filing of a request by the permittee for a permit modification, revocation or reissuance, termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

6. Toxic Pollutants

The permittee must comply with any applicable effluent standards or prohibitions established under Oregon Administrative Rules (OAR) 340-041-0033 and 307(a) of the federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under Section 405(d) of the Clean Water Act within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

7. Property Rights and Other Legal Requirements

The issuance of this permit does not convey any property rights of any sort, or any exclusive privilege, or authorize any injury to persons or property or invasion of any other private rights, or any infringement of federal, tribal, state, or local laws or regulations.

8. Permit References

Except for effluent standards or prohibitions established under Section 307(a) of the federal Clean Water Act and OAR 340-041-0033 for toxic pollutants and standards for sewage sludge use or disposal established under Section 405(d) of the Clean Water Act, all rules and statutes referred to in this permit are those in effect on the date this permit is issued.

9. Permit Fees

The permittee must pay the fees required by Oregon Administrative Rules.



**SECTION B. OPERATION AND MAINTENANCE OF POLLUTION CONTROLS**

1. Proper Operation and Maintenance  
The permittee must at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems that are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.
  
2. Need to Halt or Reduce Activity Not a Defense  
For industrial or commercial facilities, upon reduction, loss, or failure of the treatment facility, the permittee must, to the extent necessary to maintain compliance with its permit, control production or all discharges or both until the facility is restored or an alternative method of treatment is provided. This requirement applies, for example, when the primary source of power of the treatment facility fails or is reduced or lost. It is not a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
  
3. Bypass of Treatment Facilities
  - a. Definitions
    - (1) "Bypass" means intentional diversion of waste streams from any portion of the treatment facility. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, provided the diversion is to allow essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs b. and c. of this section.
    - (2) "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
  - b. Prohibition of bypass.
    - (1) Bypass is prohibited and the Department may take enforcement action against a permittee for bypass unless:
      - (a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
      - (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate backup equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventative maintenance; and
      - (c) The permittee submitted notices and requests as required under General Condition B.3.e.
    - (2) The Department may approve an anticipated bypass, after considering its adverse effects and any alternatives to bypassing, when the Department determines that it will meet the three conditions listed above in General Condition B.3.b.(1).
  - c. Notice and request for bypass.
    - (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, a written notice must be submitted to the Department at least ten days before the date of the bypass.

- (2) Unanticipated bypass. The permittee must submit notice of an unanticipated bypass as required in General Condition D.5.

4. Upset

- a. Definition. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operation error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventative maintenance, or careless or improper operation.
- b. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of General Condition B.4.c are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- c. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset must demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - (1) An upset occurred and that the permittee can identify the causes(s) of the upset;
  - (2) The permitted facility was at the time being properly operated;
  - (3) The permittee submitted notice of the upset as required in General Condition D.5, hereof (24-hour notice); and
  - (4) The permittee complied with any remedial measures required under General Condition A.3 hereof.
- d. Burden of proof. In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof.

5. Treatment of Single Operational Upset

For purposes of this permit, A Single Operational Upset that leads to simultaneous violations of more than one pollutant parameter will be treated as a single violation. A single operational upset is an exceptional incident that causes simultaneous, unintentional, unknowing (not the result of a knowing act or omission), temporary noncompliance with more than one Clean Water Act effluent discharge pollutant parameter. A single operational upset does not include Clean Water Act violations involving discharge without a NPDES permit or noncompliance to the extent caused by improperly designed or inadequate treatment facilities. Each day of a single operational upset is a violation.

6. Public Notification of Effluent Violation

If effluent limitations specified in this permit are exceeded or an overflow occurs that threatens public health, the permittee must take such steps as are necessary to alert the public, health agencies and other affected entities (e.g., public water systems) about the extent and nature of the discharge in accordance with the notification procedures developed in accordance with General Condition B.7. Such steps may include, but are not limited to, posting of the river at access points and other places, news releases, and paid announcements on radio and television.

7. Emergency Response and Public Notification Plan

The permittee must develop and implement an emergency response and public notification plan that identifies measures to protect public health from bypasses or upsets that may endanger public health. At a minimum the plan must include mechanisms to:

- a. Ensure that the permittee is aware (to the greatest extent possible) of such events;
- b. Ensure notification of appropriate personnel and ensure that they are immediately dispatched for investigation and response;

- c. Ensure immediate notification to the public, health agencies, and other affected entities (including public water systems). The response plan must identify the public health and other officials who will receive immediate notification;
- d. Ensure that appropriate personnel are aware of and follow the plan and are appropriately trained;
- e. Provide emergency operations: and
- f. Ensure that DEQ is notified of the public notification steps taken.

8. Removed Substances

Solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters must be disposed of in such a manner as to prevent any pollutant from such materials from entering waters of the state, causing nuisance conditions, or creating a public health hazard.

**SECTION C. MONITORING AND RECORDS**

1. Representative Sampling

Sampling and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. All samples shall be taken at the monitoring points specified in this permit, and shall be taken, unless otherwise specified, before the effluent joins or is diluted by any other waste stream, body of water, or substance. Monitoring points may not be changed without notification to and approval of the Department.

2. Flow Measurements

Appropriate flow measurement devices and methods consistent with accepted scientific practices must be selected and used to ensure the accuracy and reliability of measurements of the volume of monitored discharges. The devices must be installed, calibrated and maintained to insure that the accuracy of the measurements is consistent with the accepted capability of that type of device. Devices selected must be capable of measuring flows with a maximum deviation of less than  $\pm 10$  percent from true discharge rates throughout the range of expected discharge volumes.

3. Monitoring Procedures

Monitoring must be conducted according to test procedures approved under 40 CFR part 136, or in the case of sludge use and disposal, under 40 CFR part 503, unless other test procedures have been specified in this permit.

4. Penalties of Tampering

The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit may, upon conviction, be punished by a fine of not more than \$10,000 per violation, imprisonment for not more than two years, or both. If a conviction of a person is for a violation committed after a first conviction of such person, punishment is a fine not more than \$20,000 per day of violation, or by imprisonment of not more than four years, or both.

5. Reporting of Monitoring Results

Monitoring results must be summarized each month on a Discharge Monitoring Report form approved by the Department. The reports must be submitted monthly and are to be mailed, delivered or otherwise transmitted by the 15th day of the following month unless specifically approved otherwise in Schedule B of this permit.

6. Additional Monitoring by the Permittee

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR part 136 or, in the case of sludge use and disposal, under 40 CFR part 503, or as specified in this permit, the results of this monitoring must be included in the calculation and reporting of the data submitted in the Discharge Monitoring Report. Such increased frequency must also be indicated. For a pollutant parameter that may be sampled more than once per day (e.g., Total Chlorine Residual), only the average daily value must be recorded unless otherwise specified in this permit.

7. Averaging of Measurements

Calculations for all limitations that require averaging of measurements must utilize an arithmetic mean, except for bacteria which shall be averaged as specified in this permit.

8. Retention of Records

Records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities shall be retained for a period of at least five years (or longer as required by 40 CFR part 503). Records of all monitoring information including all calibration and maintenance records, all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit and records of all data used to complete the application for this permit shall be retained for a period of at least 3 years from the date of the sample, measurement, report, or application. This period may be extended by request of the Department at any time.

9. Records Contents

Records of monitoring information must include:

- a. The date, exact place, time, and methods of sampling or measurements;
- b. The individual(s) who performed the sampling or measurements;
- c. The date(s) analyses were performed;
- d. The individual(s) who performed the analyses;
- e. The analytical techniques or methods used; and
- f. The results of such analyses.

10. Inspection and Entry

The permittee must allow the Department or EPA upon the presentation of credentials, to:

- a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit, and
- d. Sample or monitor at reasonable times, for the purpose of assuring permit compliance or as otherwise authorized by state law, any substances or parameters at any location.

11. Confidentiality of Information

Any information relating to this permit that is submitted to or obtained by DEQ is available to the public unless classified as confidential by the Director of DEQ under ORS 468.095. The Permittee may request that information be classified as confidential if it is a trade secret as defined by that statute. The name and address of the permittee, permit applications, permits, effluent data, and information required by NPDES application forms under 40 CFR 122.21 will not be classified as confidential. 40 CFR 122.7(b).

## **SECTION D. REPORTING REQUIREMENTS**

1. **Planned Changes**  
The permittee must comply with OAR chapter 340, division 52, "Review of Plans and Specifications" and 40 CFR Section 122.41(l) (1). Except where exempted under OAR chapter 340, division 52, no construction, installation, or modification involving disposal systems, treatment works, sewerage systems, or common sewers may be commenced until the plans and specifications are submitted to and approved by the Department. The permittee must give notice to the Department as soon as possible of any planned physical alternations or additions to the permitted facility.
2. **Anticipated Noncompliance**  
The permittee must give advance notice to the Department of any planned changes in the permitted facility or activity that may result in noncompliance with permit requirements.
3. **Transfers**  
This permit may be transferred to a new permittee provided the transferee acquires a property interest in the permitted activity and agrees in writing to fully comply with all the terms and conditions of the permit and the rules of the Commission. No permit may be transferred to a third party without prior written approval from the Department. The Department may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under 40 CFR Section 122.61. The permittee must notify the Department when a transfer of property interest takes place.
4. **Compliance Schedule**  
Reports of compliance or noncompliance with, or any progress reports on interim and final requirements contained in any compliance schedule of this permit must be submitted no later than 14 days following each schedule date. Any reports of noncompliance must include the cause of noncompliance, any remedial actions taken, and the probability of meeting the next scheduled requirements.
5. **Twenty-Four Hour Reporting**  
The permittee must report any noncompliance that may endanger health or the environment. Any information must be provided orally (by telephone) within 24 hours from the time the permittee becomes aware of the circumstances, unless a shorter time is specified in the permit. During normal business hours, the Department's Regional office must be called. Outside of normal business hours, the Department must be contacted at 1-800-452-0311 (Oregon Emergency Response System).

The following must be included as information that must be reported within 24 hours under this paragraph:

- a. Any unanticipated bypass that exceeds any effluent limitation in this permit;
- b. Any upset that exceeds any effluent limitation in this permit;
- c. Violation of maximum daily discharge limitation for any of the pollutants listed by the Department in this permit; and
- d. Any noncompliance that may endanger human health or the environment.

A written submission must also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission must contain:

- e. A description of noncompliance and its cause;
- f. The period of noncompliance, including exact dates and times;
- g. The estimated time noncompliance is expected to continue if it has not been corrected;

- h. Steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and
- i. Public notification steps taken, pursuant to General Condition B.7.

The Department may waive the written report on a case-by-case basis if the oral report has been received within 24 hours.

6. Other Noncompliance

The permittee must report all instances of noncompliance not reported under General Condition D.4 or D.5, at the time monitoring reports are submitted. The reports must contain:

- a. A description of the noncompliance and its cause;
- b. The period of noncompliance, including exact dates and times;
- c. The estimated time noncompliance is expected to continue if it has not been corrected; and
- d. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

7. Duty to Provide Information

The permittee must furnish to the Department within a reasonable time any information that the Department may request to determine compliance with the permit or to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit. The permittee must also furnish to the Department, upon request, copies of records required to be kept by this permit.

Other Information: When the permittee becomes aware that it has failed to submit any relevant facts or has submitted incorrect information in a permit application or any report to the Department, it must promptly submit such facts or information.

8. Signatory Requirements

All applications, reports or information submitted to the Department must be signed and certified in accordance with 40 CFR Section 122.22.

9. Falsification of Information

Under ORS 468.953, any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance, is subject to a Class C felony punishable by a fine not to exceed \$100,000 per violation and up to 5 years in prison. Additionally, according to 40 CFR 122.41(k)(2), any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a federal civil penalty not to exceed \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.

10. Changes to Discharges of Toxic Pollutant

The permittee must notify the Department as soon as it knows or has reason to believe the following:

- a. That any activity has occurred or will occur that would result in the discharge, on a routine or frequent basis, of any toxic pollutant that is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:
  - (1) One hundred micrograms per liter (100 µg/l);
  - (2) Two hundred micrograms per liter (200 µg/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/l) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;

- (3) Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR Section 122.21(g)(7); or
  - (4) The level established by the Department in accordance with 40 CFR Section 122.44(f).
- b. That any activity has occurred or will occur that would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant that is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
- (1) Five hundred micrograms per liter (500 µg/l);
  - (2) One milligram per liter (1 mg/l) for antimony;
  - (3) Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR Section 122.21(g)(7); or
  - (4) The level established by the Department in accordance with 40 CFR Section 122.44(f).

#### **SECTION E. DEFINITIONS**

1. *BOD* means five-day biochemical oxygen demand.
2. *CBOD* means five day carbonaceous biochemical oxygen demand.
3. *TSS* means total suspended solids.
4. "*Bacteria*" includes but is not limited to fecal coliform bacteria, total coliform bacteria, and *E. coli* bacteria.
5. *FC* means fecal coliform bacteria.
6. *Total residual chlorine* means combined chlorine forms plus free residual chlorine
7. *Technology based permit effluent limitations* means technology-based treatment requirements as defined in 40 CFR Section 125.3, and concentration and mass load effluent limitations that are based on minimum design criteria specified in OAR Chapter 340, Division 41.
8. *mg/l* means milligrams per liter.
9. *kg* means kilograms.
10. *m<sup>3</sup>/d* means cubic meters per day.
11. *MGD* means million gallons per day.
12. *24-hour Composite sample* means a combination of at least six discrete sample aliquots of at least 100 milliliters, collected at periodic intervals from the same location, during the operating hours of the facility over a 24 hour period. Four (rather than six) aliquots should be collected for volatile organics analyses. The composite must be flow or time proportional, whichever is more appropriate. The sample aliquots must be collected and stored in accordance with procedures prescribed in the most recent edition of *Standard Methods for the Examination of Water and Wastewater*.
13. *Grab sample* means an individual discrete sample collected over a period of time not to exceed 15 minutes.
14. *Quarter* means January through March, April through June, July through September, or October through December.
15. *Month* means calendar month.
16. *Week* means a calendar week of Sunday through Saturday.

(

(

.....

.....