

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM  
 WASTE DISCHARGE PERMIT**

Department of Environmental Quality  
 Eastern Region  
 700 S.E. Emigrant Avenue, Suite #330, Pendleton, OR 97801  
 Telephone: (541) 276-4063

Issued pursuant to ORS 468B.050 and the Federal Clean Water Act

<b>FACILITY:</b>	<b>SOURCES COVERED BY THIS PERMIT:</b>		
City of Mt. Vernon P.O. Box 647 Mt. Vernon, OR 97865	<u>Type of Waste</u>	<u>Outfall</u>	<u>Location</u>
	Treated Domestic Wastewater	001	RM 239

<b>PLANT TYPE AND LOCATION:</b>	<b>RIVER BASIN INFORMATION:</b>
Four Cell Facultative Lagoon System South of City on Ingle Street Mt. Vernon, Oregon	Basin: John Day Sub-Basin: Upper John Day LLID: 1206499457318 - 239D County: Grant
EPA Reference No.: OR003069-4	Applicable Standards: OAR 340-41

Issued in response to Application No.972311 received 11-20-2008.

This permit is issued based on the land use findings in the permit record.

Cheryll Hutchens-Woods  
 Cheryll Hutchens-Woods, Water Quality Manager  
 Eastern Region-Pendleton

December 29, 2011  
 Date

**PERMITTED ACTIVITIES**

Until this permit expires or is modified or revoked, the Permittee is authorized to construct, install, modify, or operate a wastewater collection, treatment, control and disposal system to discharge to waters of the State adequately treated wastewaters only from the authorized discharge point or points established in Schedule A and only in conformance with all the requirements, limitations, and conditions set forth in the attached schedules as follows:

	<u>Page</u>
Schedule A - Waste Discharge/Disposal Limitations not to be Exceeded .....	2-3
Schedule B - Minimum Monitoring and Reporting Requirements .....	4-6
Schedule C - Compliance Conditions and Schedules.....	7
Schedule D - Special Conditions.....	8-9
Schedule E - Not Applicable .....	--
Schedule F - General Conditions.....	10-17

Unless specifically authorized by this permit, by another NPDES or WPCF permit, or by Oregon Administrative Rule, any other direct or indirect discharge to waters of the state is prohibited, including discharge to an underground injection control system.

**SCHEDULE A**

**Waste Discharge Limitations**

1. Outfall 001 (Wastewater Treatment Plant Discharge)

- a. Discharge Prohibited. (unless by written Department approval)

The Department will consider future discharge approval only after receipt of the Mixing Zone/Water Quality Criteria Analysis (MZ/WQCA) report required in Schedule B of this permit.

- b. Technology-Based Effluent Limits (TBELs)

Parameter	Average Effluent Concentrations (mg/L)		Monthly* Average (lb/day)	Weekly* Average (lb/day)	Daily* Maximum (lbs)
	Monthly	Weekly			
BOD <sub>5</sub>	30	45	25	38	50
TSS	85	140	71	110	140
Limitation					
BOD <sub>5</sub>	Monthly average must not be less than 85%				
TSS	Monthly average must not be less than 65% (lagoon)				
pH	Must be within range of 6.0-9.0 s.u.				

\* Mass load limits based on average dry weather design flow of 0.10 MGD from the facility.

- c. Water Quality-Based Effluent Limits (WQBELs)

Parameter	Limitations
<i>E. coli</i> Bacteria	Shall not exceed 126 organisms per 100 ml monthly log mean. No single sample shall exceed 406 organisms per 100 ml. (See Note 1)
Total Residual Chlorine Concentration	Shall not exceed a daily average of 0.05 mg/l. (See Note 2)

Additional WQBELs may be established by Department permit modification after receipt of the MZ/WQCA report required in Schedule B of this permit.

2. Except as provided for in OAR 340-45-080, no wastes shall be discharged and no activities shall be conducted which violate Water Quality Standards as adopted in OAR 340-041-0605, except in the following defined mixing zones:

The allowable mixing zone shall not exceed beyond a radius of 400 feet from the point of discharge into the John Day River. In addition, the Zone of Immediate Dilution (ZID) shall not exceed 10 percent of the defined mixing zone in any one direction from the point of discharge. (See Note 2)

3. All wastes shall be managed and disposed in a manner that will prevent:

- a. A violation of the Department's Groundwater Quality Protection Rules (OAR Chapter 340, Division 040); and  
b. A violation of any permit-specific groundwater concentration limits, established pursuant to OAR 340-040-0030, which have been incorporated into the permit by addendum.

4. The Department may reopen this permit to include new and/or revised waste discharge limitations.

**NOTES:**

1. If a single sample exceeds 406 organisms per 100 ml, then five consecutive re-samples may be taken at four-hour intervals beginning within 28 hours after the original sample was taken. If the log mean of the five re-samples is less than or equal to 126 organisms per 100 ml, a violation shall not be triggered.
2. When the permittee completes a dilution and mixing zone study (See Schedule C, Condition 2), the Department may reopen this permit to revise the total residual chlorine limit and/or the defined mixing zone, as appropriate.

**SCHEDULE B****Minimum Monitoring and Reporting Requirements (unless otherwise approved in writing by the Department)**

1. The Department may reopen this permit to include new and/or revised monitoring and/or reporting requirements.
2. **Monitoring Requirements**

The permittee shall monitor the parameters as specified below at the locations indicated. The laboratory used by the permittee to analyze samples shall have a quality assurance/quality control (QA/QC) program to verify the accuracy of sample analysis. If QA/QC requirements are not met for any analysis, the results shall be included in the report, but not used in calculations required by this permit. When possible, the permittee shall re-sample in a timely manner for parameters failing the QA/QC requirements, analyze the samples, and report the results.

## a. Influent

Item or Parameter	Minimum Frequency	Type of Sample/Action
Total Flow (MGD)	Daily	Record Measurement
Flow Meter Calibration	Annually	Provide Verification
BOD <sub>5</sub>	Monthly	Composite (See Note 1)
TSS	Monthly	Composite (See Note 1)
pH	Twice Weekly	Grab

## b. Lagoon site (All year)

Item or Parameter	Minimum Frequency	Type of Sample/Action
Perimeter inspection	5 days per week	Document Event
Lagoon level	Weekly	Record Measurement

## c. Treated Effluent-Outfall 001 (when discharging to John Day River)

Item or Parameter	Minimum Frequency	Type of Sample/Action
Total Flow (MGD)	Daily	Record Measurement
Flow Meter Calibration	Annually	Provide Verification
BOD <sub>5</sub> , mg/L	Monthly	Composite (See Note 1)
TSS, mg/l	Monthly	Composite (See Note 1)
pH, s.u.	Twice Weekly	Grab
<i>E. coli</i> Bacteria, CFU/100ml	Monthly	Grab (See Note 2)
Quantity Chlorine Used, lbs	Daily	Record Measurement
Total Chlorine Residual, mg/L	Daily	Grab
Temperature, deg. C	Daily Maximum	Grab
Total Ammonia, mg/L	Monthly	Composite
Pounds Discharged (BOD <sub>5</sub> & TSS)	Monthly	Perform Calculation
Average % Removal (BOD <sub>5</sub> & TSS)	Monthly	Perform Calculation

d. John Day River (when discharging to John Day River)

Item or Parameter	Minimum Frequency	Type of Sample/Action
Flow (cfs)	Daily (when discharging)	Record Measurement
Temperature	Daily	Grab
Total Ammonia, mg/L	Weekly	Grab

3. Reporting Requirements

a. Monthly Discharge Monitoring Report (DMR)

- A. The monthly DMR must be submitted on a form approved by the Department.
- B. The reporting period is the calendar month.
- C. The completed DMR form must be submitted to the Department's Pendleton office by the 15th day of the following month.
- D. The DMR must always include those items listed in Schedule B- (1)(a) and (1)(b). Additionally, when discharging to the John day River, the DMR must include those items in Schedule B-(1)(c) and (1)(d).
- E. The DMR must display the treatment and collections system classifications as found on page one of this permit, and identify the name, certificate classification, and grade level of each principal operator designated by the permittee as responsible for supervising the wastewater collection and treatment systems during the reporting period.
- F. The permittee must keep are record of significant daily events including equipment failure, breakdowns, bypassing, sewage overflows to the land surface and/or surface water.
- G. The permittee must respond to the four questions on page 2 of the DMR and provide the information listed below:
  - (1) If all permit-required monitoring was not performed, the permittee must attach a written description of the monitoring that was not performed and the measures taken to ensure that all permit-required monitoring is completed in the following month.
  - (2) If permit-required monitoring documents violation of a permit limitation, the permittee must attach a written description of each violation and the measures taken to ensure compliance with all permit limitations in the following month.
  - (3) If any violation of permit limitations was the result of an unanticipated bypass or upset the permittee must attach a written description of each event.
  - (4) When sewer system overflow occur, permittee must follow the overflow reporting requirements listed in Schedule F of this permit.
- H. The DMR must include a record of the quantity and method of use of all sludge removed from the treatment facility, unless the Department has provided written approval of an alternative reporting method.

b. **Mixing Zone/Water Quality Criteria Analysis Report**

Prior to any future Department consideration of allowing direct discharge to Long Creek, the permittee must submit a Mixing Zone/Water Quality Criteria Analysis (MZ/WQCA). The MZ/WQCA report must be submitted 12 calendar months prior to any proposed discharge to Long Creek. The MZ/WQCA report must include a mixing zone dilution study using dye or an approved and verified mathematical model and should include a characterization of the zone of immediate dilution and the mixing zone boundary. Other mixing zone study methodologies may be used with written approval from the Department. The report must include an evaluation of the dispersion, mixing and dilution of the discharged effluent and should be representative of critical low flow conditions and the average dry weather flow for the facility. The report must also evaluate the facility's ability to comply with all water quality criteria, including, but not limited to, chlorine, ammonia, dissolved oxygen and temperature. If report findings determine that the facility is unable to meet specific water quality criteria, the report must identify the facility improvements necessary to achieve compliance with that particular parameter.

c. **Annual Inflow and Infiltration Report**

By no later than April 1 of each year, the permittee must submit to the Department an annual report which details collection system maintenance activities that reduce inflow and infiltration. The report must include those activities that have been completed in the previous year and those activities planned for the year to come.

**NOTES:**

1. Composite samples shall consist of no less than six (6) samples collected over a 10-hour period and apportioned according to the volume of flow at the time of sampling.
2. *E. coli* monitoring must be conducted according to any of the following test procedures as specified in **Standard Methods for the Examination of Water and Wastewater, 19th Edition**, or according to any test procedure that has been authorized and approved in writing by the Director or his authorized representative:

<b>Method</b>	<b>Reference</b>	<b>Page</b>	<b>Method Number</b>
mTEC agar, MF	Standard Methods, 18th Edition	9-29	9213 D
NA-MUG, MF	Standard Methods, 19th Edition	9-63	9222 G
Chromogenic Substrate, MPN	Standard Methods, 19th Edition	9-65	9223 B
Colilert QT	Idexx Laboratories, Inc.		

**SCHEDULE C**

N/A

## SCHEDULE D

### Special Conditions

1. An adequate contingency plan for prevention and handling of spills and unplanned discharges shall be in force at all times. A continuing program of employee orientation and education shall be maintained to ensure awareness of the necessity of good in-plant control and quick and proper action in the event of a spill or accident.
2. Not later than six (6) months prior to disposal of sludge (biosolids), the permittee shall submit a Biosolids Management Plan in accordance with Oregon Administrative Rules, Chapter 340, Division 50, "Land Application and Disposal of Sewage Treatment Plant Sludge and Sludge Derived Products Including Septage". Upon approval of the plan by the Department, all biosolids must be managed according the approved plan. This permit may be modified to incorporate any applicable standard for biosolids use or disposal promulgated under section 405(d) of the Clean Water Act, if the standard for biosolids use or disposal is more stringent than any requirements for biosolids use or disposal in the permit, or controls a pollutant or practice not limited in this permit.
3. The permittee shall comply with Oregon Administrative Rules (OAR), Chapter 340, Division 49, "Regulations Pertaining To Certification of Wastewater System Operator Personnel" and accordingly:
  - a. The permittee shall have its wastewater system supervised by one or more operators who are certified in a classification and grade level (equal to or greater) that corresponds with the classification (collection and/or treatment) of the system to be supervised as specified on page one of this permit.

**Note:** A "supervisor" is defined as the person exercising authority for establishing and executing the specific practice and procedures of operating the system in accordance with the policies of the permittee and requirements of the waste discharge permit. "Supervise" means to be responsible for the technical operation of a system, which may affect its performance or the quality of the effluent produced. Supervisors are not required to be on-site at all times.

- b. The permittee's wastewater system may not be without supervision (as required by Special Condition 3.a. above) for more than thirty (30) days. During this period, and at any time that the supervisor is not available to respond on-site (i.e. vacation, sick leave or off-call), the permittee must make available another person who is certified in the proper classification and at grade level I or higher.
- c. The permittee is responsible for ensuring the wastewater system has a properly certified supervisor available at all times to respond on-site at the request of the permittee and to any other operator.
- d. The permittee shall notify the Department in writing within thirty (30) days of replacement or redesignation of certified operators responsible for supervising wastewater system operation. The notice shall be filed with the Water Quality Division, Operator Certification Program, 811 SW 6th Ave, Portland, OR 97204. This requirement is in addition to the reporting requirements contained under Schedule B of this permit.
- e. Upon written request, the Department may grant the permittee reasonable time, not to exceed 120 days, to obtain the services of a qualified person to supervise the wastewater system. The written request must include justification for the time needed, a schedule for recruiting and hiring, the date the system supervisor availability ceased, and the name of the alternate system supervisor(s) as required by 3.b. above.



4. The permittee shall notify the DEQ Eastern Region - Pendleton Office (phone: (541- 276-4063) in accordance with the response times noted in the General Conditions of this permit, of any malfunction so that corrective action can be coordinated between the permittee and the Department.
5. The Department may reopen the permit to include new and/or revised special conditions.

**SCHEDULE F**  
**NPDES GENERAL CONDITIONS – DOMESTIC FACILITIES**

**SECTION A. STANDARD CONDITIONS****A1. Duty to Comply with Permit**

The permittee must comply with all conditions of this permit. Failure to comply with any permit condition is a violation of Oregon Revised Statutes (ORS) 468B.025 and the federal Clean Water Act and is grounds for an enforcement action. Failure to comply is also grounds for DEQ to terminate, modify and reissue, revoke, or deny renewal of a permit.

**A2. Penalties for Water Pollution and Permit Condition Violations**

The permit is enforceable by DEQ or EPA, and in some circumstances also by third-parties under the citizen suit provisions 33 USC § 1365. DEQ enforcement is generally based on provisions of state statutes and Environmental Quality Commission (EQC) rules, and EPA enforcement is generally based on provisions of federal statutes and EPA regulations.

ORS 468.140 allows DEQ to impose civil penalties up to \$10,000 per day for violation of a term, condition, or requirement of a permit. The federal Clean Water Act provides for civil penalties not to exceed \$32,500 and administrative penalties not to exceed \$11,000 per day for each violation of any condition or limitation of this permit.

Under ORS 468.943, unlawful water pollution, if committed by a person with criminal negligence, is punishable by a fine of up to \$25,000, imprisonment for not more than one year, or both. Each day on which a violation occurs or continues is a separately punishable offense. The federal Clean Water Act provides for criminal penalties of not more than \$50,000 per day of violation, or imprisonment of not more than 2 years, or both for second or subsequent negligent violations of this permit.

Under ORS 468.946, a person who knowingly discharges, places, or causes to be placed any waste into the waters of the state or in a location where the waste is likely to escape into the waters of the state is subject to a Class B felony punishable by a fine not to exceed \$250,000 and up to 10 years in prison. ORS 161. The federal Clean Water Act provides for criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment of not more than 3 years, or both for knowing violations of the permit. In the case of a second or subsequent conviction for knowing violation, a person is subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both.

**A3. Duty to Mitigate**

The permittee must take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit that has a reasonable likelihood of adversely affecting human health or the environment. In addition, upon request of DEQ, the permittee must correct any adverse impact on the environment or human health resulting from noncompliance with this permit, including such accelerated or additional monitoring as necessary to determine the nature and impact of the noncomplying discharge.

**A4. Duty to Reapply**

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and have the permit renewed. The application must be submitted at least 180 days before the expiration date of this permit.

DEQ may grant permission to submit an application less than 180 days in advance but no later than the permit expiration date.

**A5. Permit Actions**

This permit may be modified, revoked and reissued, or terminated for cause including, but not limited to, the following:

- a. Violation of any term, condition, or requirement of this permit, a rule, or a statute.
- b. Obtaining this permit by misrepresentation or failure to disclose fully all material facts.
- c. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.
- d. The permittee is identified as a Designated Management Agency or allocated a wasteload under a total maximum daily load (TMDL).
- e. New information or regulations.
- f. Modification of compliance schedules.

- g. Requirements of permit reopener conditions
- h. Correction of technical mistakes made in determining permit conditions.
- i. Determination that the permitted activity endangers human health or the environment.
- j. Other causes as specified in 40 CFR §§ 122.62, 122.64, and 124.5.
- k. For communities with combined sewer overflows (CSOs):
  - (1) To comply with any state or federal law regulation for CSOs that is adopted or promulgated subsequent to the effective date of this permit.
  - (2) If new information that was not available at the time of permit issuance indicates that CSO controls imposed under this permit have failed to ensure attainment of water quality standards, including protection of designated uses.
  - (3) Resulting from implementation of the permittee's long-term control plan and/or permit conditions related to CSOs.

The filing of a request by the permittee for a permit modification, revocation or reissuance, termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

**A6. Toxic Pollutants**

The permittee must comply with any applicable effluent standards or prohibitions established under Oregon Administrative Rule (OAR) 340-041-0033 and section 307(a) of the federal Clean Water Act for toxic pollutants, and with standards for sewage sludge use or disposal established under section 405(d) of the federal Clean Water Act, within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

**A7. Property Rights and Other Legal Requirements**

The issuance of this permit does not convey any property rights of any sort, or any exclusive privilege, or authorize any injury to persons or property or invasion of any other private rights, or any infringement of federal, tribal, state, or local laws or regulations.

**A8. Permit References**

Except for effluent standards or prohibitions established under section 307(a) of the federal Clean Water Act and OAR 340-041-0033 for toxic pollutants, and standards for sewage sludge use or disposal established under section 405(d) of the federal Clean Water Act, all rules and statutes referred to in this permit are those in effect on the date this permit is issued.

**A9. Permit Fees**

The permittee must pay the fees required by OAR.

**SECTION B. OPERATION AND MAINTENANCE OF POLLUTION CONTROLS**

**B1. Proper Operation and Maintenance**

The permittee must at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems that are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

**B2. Need to Halt or Reduce Activity Not a Defense**

For industrial or commercial facilities, upon reduction, loss, or failure of the treatment facility, the permittee must, to the extent necessary to maintain compliance with its permit, control production or all discharges or both until the facility is restored or an alternative method of treatment is provided. This requirement applies, for example, when the primary source of power of the treatment facility fails or is reduced or lost. It is not a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

**B3. Bypass of Treatment Facilities**

**a. Definitions**

- (1) "Bypass" means intentional diversion of waste streams from any portion of the treatment facility. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, provided the diversion

is to allow essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs b and c of this section.

- (2) "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
- b. Prohibition of bypass.
  - (1) Bypass is prohibited and DEQ may take enforcement action against a permittee for bypass unless:
    - i. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
    - ii. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate backup equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventative maintenance; and
    - iii. The permittee submitted notices and requests as required under General Condition B3.c.
  - (2) DEQ may approve an anticipated bypass, after considering its adverse effects and any alternatives to bypassing, if DEQ determines that it will meet the three conditions listed above in General Condition B3.b.(1).
- c. Notice and request for bypass.
  - (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, a written notice must be submitted to DEQ at least ten days before the date of the bypass.
  - (2) Unanticipated bypass. The permittee must submit notice of an unanticipated bypass as required in General Condition D5.

#### B4. Upset

- a. Definition. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operation error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventative maintenance, or careless or improper operation.
- b. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of General Condition B4.c are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- c. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset must demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
  - (2) The permitted facility was at the time being properly operated;
  - (3) The permittee submitted notice of the upset as required in General Condition D5, hereof (24-hour notice); and
  - (4) The permittee complied with any remedial measures required under General Condition A3 hereof.
- d. Burden of proof. In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof.

#### B5. Treatment of Single Operational Upset

For purposes of this permit, a single operational upset that leads to simultaneous violations of more than one pollutant parameter will be treated as a single violation. A single operational upset is an exceptional incident that causes simultaneous, unintentional, unknowing (not the result of a knowing act or omission), temporary noncompliance with more than one federal Clean Water Act effluent discharge pollutant parameter. A single operational upset does not include federal Clean Water Act violations involving discharge without a NPDES permit or noncompliance to the extent caused by improperly designed or inadequate treatment facilities. Each day of a single operational upset is a violation.

#### B6. Overflows from Wastewater Conveyance Systems and Associated Pump Stations

- a. Definition. "Overflow" means any spill, release or diversion of sewage including:
  - (1) An overflow that results in a discharge to waters of the United States; and
  - (2) An overflow of wastewater, including a wastewater backup into a building (other than a backup caused solely by a blockage or other malfunction in a privately owned sewer or building lateral), even if that overflow does not reach waters of the United States.

- b. Prohibition of overflows. Overflows are prohibited. DEQ may exercise enforcement discretion regarding overflow events. In exercising its enforcement discretion, DEQ may consider various factors, including the adequacy of the conveyance system's capacity and the magnitude, duration and return frequency of storm events.
- c. Reporting required. All overflows must be reported orally to DEQ within 24 hours from the time the permittee becomes aware of the overflow. Reporting procedures are described in more detail in General Condition D5.

**B7. Public Notification of Effluent Violation or Overflow**

If effluent limitations specified in this permit are exceeded or an overflow occurs that threatens public health, the permittee must take such steps as are necessary to alert the public, health agencies and other affected entities (for example, public water systems) about the extent and nature of the discharge in accordance with the notification procedures developed under General Condition B8. Such steps may include, but are not limited to, posting of the river at access points and other places, news releases, and paid announcements on radio and television.

**B8. Emergency Response and Public Notification Plan**

The permittee must develop and implement an emergency response and public notification plan that identifies measures to protect public health from overflows, bypasses, or upsets that may endanger public health. At a minimum the plan must include mechanisms to:

- a. Ensure that the permittee is aware (to the greatest extent possible) of such events;
- b. Ensure notification of appropriate personnel and ensure that they are immediately dispatched for investigation and response;
- c. Ensure immediate notification to the public, health agencies, and other affected public entities (including public water systems). The overflow response plan must identify the public health and other officials who will receive immediate notification;
- d. Ensure that appropriate personnel are aware of and follow the plan and are appropriately trained;
- e. Provide emergency operations; and
- f. Ensure that DEQ is notified of the public notification steps taken.

**B9. Removed Substances**

Solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters must be disposed of in such a manner as to prevent any pollutant from such materials from entering waters of the state, causing nuisance conditions, or creating a public health hazard.

**SECTION C. MONITORING AND RECORDS**

**C1. Representative Sampling**

Sampling and measurements taken as required herein must be representative of the volume and nature of the monitored discharge. All samples must be taken at the monitoring points specified in this permit, and must be taken, unless otherwise specified, before the effluent joins or is diluted by any other waste stream, body of water, or substance. Monitoring points must not be changed without notification to and the approval of DEQ.

**C2. Flow Measurements**

Appropriate flow measurement devices and methods consistent with accepted scientific practices must be selected and used to ensure the accuracy and reliability of measurements of the volume of monitored discharges. The devices must be installed, calibrated and maintained to insure that the accuracy of the measurements is consistent with the accepted capability of that type of device. Devices selected must be capable of measuring flows with a maximum deviation of less than  $\pm 10$  percent from true discharge rates throughout the range of expected discharge volumes.

**C3. Monitoring Procedures**

Monitoring must be conducted according to test procedures approved under 40 CFR part 136 or, in the case of sludge use and disposal, approved under 40 CFR part 503 unless other test procedures have been specified in this permit.

**C4. Penalties of Tampering**

The federal Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit may, upon conviction, be punished by a fine of not more than \$10,000 per violation, imprisonment for not more than two years, or both. If a conviction of a person is for a violation committed after a first conviction of such person, punishment is a fine not more than \$20,000 per day of violation, or by imprisonment of not more than four years, or both.

C5. Reporting of Monitoring Results

Monitoring results must be summarized each month on a Discharge Monitoring Report form approved by DEQ. The reports must be submitted monthly and are to be mailed, delivered or otherwise transmitted by the 15th day of the following month unless specifically approved otherwise in Schedule B of this permit.

C6. Additional Monitoring by the Permittee

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR part 136 or, in the case of sludge use and disposal, approved under 40 CFR part 503, or as specified in this permit, the results of this monitoring must be included in the calculation and reporting of the data submitted in the discharge monitoring report. Such increased frequency must also be indicated. For a pollutant parameter that may be sampled more than once per day (for example, Total Chlorine Residual), only the average daily value must be recorded unless otherwise specified in this permit.

C7. Averaging of Measurements

Calculations for all limitations that require averaging of measurements must utilize an arithmetic mean, except for bacteria which must be averaged as specified in this permit.

C8. Retention of Records

Records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities must be retained for a period of at least 5 years (or longer as required by 40 CFR part 503). Records of all monitoring information including all calibration and maintenance records, all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit and records of all data used to complete the application for this permit must be retained for a period of at least 3 years from the date of the sample, measurement, report, or application. This period may be extended by request of DEQ at any time.

C9. Records Contents

Records of monitoring information must include:

- a. The date, exact place, time, and methods of sampling or measurements;
- b. The individual(s) who performed the sampling or measurements;
- c. The date(s) analyses were performed;
- d. The individual(s) who performed the analyses;
- e. The analytical techniques or methods used; and
- f. The results of such analyses.

C10. Inspection and Entry

The permittee must allow DEQ or EPA upon the presentation of credentials to:

- a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
- d. Sample or monitor at reasonable times, for the purpose of assuring permit compliance or as otherwise authorized by state law, any substances or parameters at any location.

C11. Confidentiality of Information

Any information relating to this permit that is submitted to or obtained by DEQ is available to the public unless classified as confidential by the Director of DEQ under ORS 468.095. The permittee may request that information be classified as confidential if it is a trade secret as defined by that statute. The name and address of the permittee, permit applications, permits, effluent data, and information required by NPDES application forms under 40 CFR § 122.21 are not classified as confidential. 40 CFR § 122.7(b).

**SECTION D. REPORTING REQUIREMENTS**

D1. Planned Changes

The permittee must comply with OAR 340-052, "Review of Plans and Specifications" and 40 CFR § 122.41(l)(1). Except where exempted under OAR 340-052, no construction, installation, or modification involving disposal systems, treatment works, sewerage systems, or common sewers may be commenced until the plans and specifications are submitted to and

approved by DEQ. The permittee must give notice to DEQ as soon as possible of any planned physical alternations or additions to the permitted facility.

D2. Anticipated Noncompliance

The permittee must give advance notice to DEQ of any planned changes in the permitted facility or activity that may result in noncompliance with permit requirements.

D3. Transfers

This permit may be transferred to a new permittee provided the transferee acquires a property interest in the permitted activity and agrees in writing to fully comply with all the terms and conditions of the permit and EQC rules. No permit may be transferred to a third party without prior written approval from DEQ. DEQ may require modification, revocation, and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under 40 CFR § 122.61. The permittee must notify DEQ when a transfer of property interest takes place.

D4. Compliance Schedule

Reports of compliance or noncompliance with, or any progress reports on interim and final requirements contained in any compliance schedule of this permit must be submitted no later than 14 days following each schedule date. Any reports of noncompliance must include the cause of noncompliance, any remedial actions taken, and the probability of meeting the next scheduled requirements.

D5. Twenty-Four Hour Reporting

The permittee must report any noncompliance that may endanger health or the environment. Any information must be provided orally (by telephone) to the DEQ regional office or Oregon Emergency Response System (1-800-452-0311) as specified below within 24 hours from the time the permittee becomes aware of the circumstances.

a. Overflows.

(1) Oral Reporting within 24 hours.

- i. For overflows other than basement backups, the following information must be reported to the Oregon Emergency Response System (OERS) at 1-800-452-0311. For basement backups, this information should be reported directly to the DEQ regional office.
  - (a) The location of the overflow;
  - (b) The receiving water (if there is one);
  - (c) An estimate of the volume of the overflow;
  - (d) A description of the sewer system component from which the release occurred (for example, manhole, constructed overflow pipe, crack in pipe); and
  - (e) The estimated date and time when the overflow began and stopped or will be stopped.
- ii. The following information must be reported to the DEQ regional office within 24 hours, or during normal business hours, whichever is earlier:
  - (a) The OERS incident number (if applicable); and
  - (b) A brief description of the event.

(2) Written reporting within 5 days.

- i. The following information must be provided in writing to the DEQ regional office within 5 days of the time the permittee becomes aware of the overflow:
  - (a) The OERS incident number (if applicable);
  - (b) The cause or suspected cause of the overflow;
  - (c) Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the overflow and a schedule of major milestones for those steps;
  - (d) Steps taken or planned to mitigate the impact(s) of the overflow and a schedule of major milestones for those steps; and
  - (e) For storm-related overflows, the rainfall intensity (inches/hour) and duration of the storm associated with the overflow.

DEQ may waive the written report on a case-by-case basis if the oral report has been received within 24 hours.

b. Other instances of noncompliance.

(1) The following instances of noncompliance must be reported:

- i. Any unanticipated bypass that exceeds any effluent limitation in this permit;
- ii. Any upset that exceeds any effluent limitation in this permit;

- iii. Violation of maximum daily discharge limitation for any of the pollutants listed by DEQ in this permit; and
  - iv. Any noncompliance that may endanger human health or the environment.
- (2) During normal business hours, the DEQ regional office must be called. Outside of normal business hours, DEQ must be contacted at 1-800-452-0311 (Oregon Emergency Response System).
- (3) A written submission must be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission must contain:
- i. A description of the noncompliance and its cause;
  - ii. The period of noncompliance, including exact dates and times;
  - iii. The estimated time noncompliance is expected to continue if it has not been corrected;
  - iv. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance; and
  - v. Public notification steps taken, pursuant to General Condition B7.
- (4) DEQ may waive the written report on a case-by-case basis if the oral report has been received within 24 hours.

**D6. Other Noncompliance**

The permittee must report all instances of noncompliance not reported under General Condition D4 or D5 at the time monitoring reports are submitted. The reports must contain:

- a. A description of the noncompliance and its cause;
- b. The period of noncompliance, including exact dates and times;
- c. The estimated time noncompliance is expected to continue if it has not been corrected; and
- d. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

**D7. Duty to Provide Information**

The permittee must furnish to DEQ within a reasonable time any information that DEQ may request to determine compliance with the permit or to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit. The permittee must also furnish to DEQ, upon request, copies of records required to be kept by this permit.

Other Information: When the permittee becomes aware that it has failed to submit any relevant facts or has submitted incorrect information in a permit application or any report to DEQ, it must promptly submit such facts or information.

**D8. Signatory Requirements**

All applications, reports or information submitted to DEQ must be signed and certified in accordance with 40 CFR § 122.22.

**D9. Falsification of Information**

Under ORS 468.953, any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance, is subject to a Class C felony punishable by a fine not to exceed \$125,000 per violation and up to 5 years in prison. ORS 161. Additionally, according to 40 CFR § 122.41(k)(2), any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit including monitoring reports or reports of compliance or non-compliance will, upon conviction, be punished by a federal civil penalty not to exceed \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.

**D10. Changes to Indirect Dischargers**

The permittee must provide adequate notice to DEQ of the following:

- a. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to section 301 or 306 of the federal Clean Water Act if it were directly discharging those pollutants and;
- b. Any substantial change in the volume or character of pollutants being introduced into the POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
- c. For the purposes of this paragraph, adequate notice must include information on (i) the quality and quantity of effluent introduced into the POTW, and (ii) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

**SECTION E. DEFINITIONS**

- E1. *BOD* or *BOD<sub>5</sub>* means five-day biochemical oxygen demand.
- E2. *CBOD* or *CBOD<sub>5</sub>* means five-day carbonaceous biochemical oxygen demand.



- E3. *TSS* means total suspended solids.
- E4. *Bacteria* means but is not limited to fecal coliform bacteria, total coliform bacteria, and *E. coli* bacteria.
- E5. *FC* means fecal coliform bacteria.
- E6. *Total residual chlorine* means combined chlorine forms plus free residual chlorine
- E7. *Technology based permit effluent limitations* means technology-based treatment requirements as defined in 40 CFR § 125.3, and concentration and mass load effluent limitations that are based on minimum design criteria specified in OAR 340-041.
- E8. *mg/l* means milligrams per liter.
- E9. *kg* means kilograms.
- E10. *m<sup>3</sup>/d* means cubic meters per day.
- E11. *MGD* means million gallons per day.
- E12. *24-hour composite sample* means a sample formed by collecting and mixing discrete samples taken periodically and based on time or flow. The sample must be collected and stored in accordance with 40 CFR part 136.
- E13. *Grab sample* means an individual discrete sample collected over a period of time not to exceed 15 minutes.
- E14. *Quarter* means January through March, April through June, July through September, or October through December.
- E15. *Month* means calendar month.
- E16. *Week* means a calendar week of Sunday through Saturday.
- E17. *POTW* means a publicly-owned treatment works.